

ELECTRIC SERVICE APPLICATION
HIBBING PUBLIC UTILITIES COMMISSION

The customer has the option to purchase meter base from the Hibbing Public Utilities or elsewhere, provided it meets the specifications outlined below:

SPECIFICATIONS

RESIDENTIAL // **Note 1** //

Manufacturer – Millbank
Size 200 Amp
U. L. Approved
Ringless Style

COMMERICAL

<u>20 Amp</u> Manufacturer - Landis & Gyr or Millbank U. L. Approved Ringless Style	<u>200 Amp</u> Manufacturer - Millbank U.L. Approved Ringless Style (Single Phase Only)
Fully rated bypass lever required	Bypass lever required

// **Note 1** // An underground meter base has knockouts on the bottom with no openings or covers on the top. An overhead meter base has a hub opening. The appropriately sized hub must also be provided with the meter base. The hub connects the conduit mast to the meter base.